

Electrical Safety Compliance Audit Checklist

	NO	
YES	Assign Target	Safety Issue
	Completion Date	
Electrical Safety Program (ESP)		
		1. Is a thorough Electrical Safety Program document available to workers?
		2. Has a comprehensive incident energy analysis been performed in the facility?
		3. Is electrical equipment labeled to warn of arc flash and shock hazards?
		4. If equipment is labeled, have these labels been kept current as the electrical distribution system has been altered?
		5. Are annual field audits performed and documented by a supervisor for all qualified electrical workers?
		6. Do qualified workers perform Job Safety Planning & Briefing before any tasks involving exposure to energized electrical equipment?
		7. Do qualified workers have and utilize barricading means to limit access into arc flash and shock hazard boundaries?
		8. Are Energized Electrical Work Permits (EEWP) available and utilized when required?
		9. Do both qualified and unqualified workers receive appropriate classroom- based electrical safety trainings every 3 years with documented attendance?
		10. Do qualified workers receive 'methods of contact release' and emergency response training on an annual basis?
Personal Protective Equipment (PPE)		
		1. Do qualified workers have arc rated uniform shirts and pants rated at a minimum 8 cal/cm ² ATPV or EBT? (ASTM F-1506)
		2. Do qualified workers have AR face shields and balaclavas (or arc flash suit hoods) rated at a minimum 8 cal/cm ² ?
		3. Do qualified workers have safety glasses?
		4. Do qualified workers have canal insert style hearing protection?
		5. Do qualified workers have insulated gloves lab tested in the last 6 months?
		6. Do qualified workers have protector gloves to wear over insulated gloves?
		7. Do qualified workers have arc flash suits (bibs/coveralls and jackets) and suit
		hoods rated at a minimum of 40 cal/cm ² ?
		8. Is PPE inspected before use, laundered properly, and in good condition?
Tools & Test Instruments		
		1. Do qualified workers have insulated tools? (ASTM F-1505 rated for 1000V)
		2. Do qualified workers have a minimum CAT III 600V rated meter? (ANSI S82)
		Do qualified workers always perform a 'live-dead-live' test with their rated meter after LOTO to establish an Electrically Safe Work Condition (ESWC)?
		4. Do qualified workers always use insulated tools for accessing electrical equipment to troubleshoot, establish an ESWC, or perform energized work?

Signature of Auditor

Date of Audit